

Ørsted

# Studstrup wood pellet silo fire

## September 2022

Chief Specialist Jens Kai Holm



# The Studstrup wood pellet silo before the fire

- Volume: 100.000 m<sup>3</sup>
- Wood pellet total capacity: 65.000 tons
- The silo was constructed in 2015 with detection systems according to best practice

## Primary Preventive barriers



- 4 smouldering fire detectors in the headspace of the silo
- 4 IR-cameras for surface temperature monitoring
- 6 thermocouple cables for bulk temperature monitoring
- Spark detection system in transfer point beneath the silo

## Primary mitigating barriers

- Nitrogen purging system based on liquid nitrogen
- Fire foam system for surface fire fighting
- One primary gate and two secondary smaller gates for emergency extraction of the wood pellets




# Root cause conclusion: Late detection of a deeply buried smouldering hotspot resulting from critical self-heating



Time : 10h   Time : 20h   Time : 30h

[Source: Henry Persson, Fire extinguishing and preventive and preparatory measures](#)

# The first indication of critical self-heating was a rapid rise in CO concentration in the silo headspace



# Intensifying pyrolysis



**Flames visible in the penthouse from the surface fire**



# Emergency emptying of the silo using remote-controlled machinery



# Main learnings from the fire in the Studstrup silo

- The fire was detected too late to be managed in a controlled way
- Temperature measurement system in the bulk of the pellets was not sufficient – no runaway temperatures were registered
- Smouldering gas detection system did not give a clear and unambiguous alarm at a sufficiently early point in time
- Insufficient system installed to control the temperature of the headspace and roof construction
- Fire foam not effective in extinguishing a surface fire on an uneven surface
- Only one gate for wheel loader access
- Challenge to maintain a high nitrogen purging capacity partly due to delivery bottlenecks

# Updated fire strategy emphasizes improved monitoring systems and proactive early prevention

## Primary Barriers & Improvements

- **Temperature monitoring:** Increased from 6 (free hanging) to 65 (fixed) thermocouples cables (~2.000 measurements)
- **Gas monitoring:** CO, CO<sub>2</sub>, and O<sub>2</sub> probes extract gases from the headspace (replacing smouldering detectors)
- **Nitrogen purging:** Continuous purging lowers oxygen; also increases gas diffusion to headspace
- **Water mist (headspace):** Sectionalized system to control headspace temperature (not for extinguishing)
- **Conveyor upgrades:** Central and side conveyors equipped with water mist and temperature sensors
- **Access:** Added two extra gates for efficient emergency emptying with wheel loaders
- **Wheel loaders:** Three remote-controlled, ATEX-approved wheel loaders shared across Ørsted sites
- **Roof monitoring:** High-temperature sensors installed on roof construction


# The reconstructed silo

Nitrogen generator building


Liquid nitrogen storage tanks



## **Sectionalized water mist system installation**



# Test of water mist system in one section



# ATEX approved, remote-controlled wheel loader



# Avedore wood pellet fire in flat storage October 2023





# Smouldering fire in flat storage was first realized when white smoke was seen from the roof top



# Root cause conclusion: The monitoring systems failed to detect the smouldering fire in time to allow a controlled response

Primary barriers	Remarks
smouldering gas detector	No clear alarms and insufficient data on absolute gas concentrations
IR surface temperature sensors	No temperatures above 45 °C was measured before Oct 19, 2023
Bi-weekly inspection with mobile IR camera	No temperatures above 45 °C was measured before Oct 19, 2023



# Images of the flat storage fire



# Images of the flat storage fire



# Images of the flat storage fire



# Thank you

# Questions?

